



GRAFTON
Massachusetts

Natalia Alward <alwardn@grafton-ma.gov>

Re: Request for Comments: PP 2021-02, "Great Rock Road" Preliminary Plan, 340-348 Providence Road

1 message

Michael Killeen <killeenm@grafton-ma.gov>
To: Natalia Alward <alwardn@grafton-ma.gov>

Tue, Oct 19, 2021 at 1:33 PM

Good afternoon,

The Fire Department would like to post the following, simply as a reminder:

The following are the minimum requirements requested by the Fire Department for new developments:

- **Street numbers:** shall be visible from the street, day and night
- **Roadways/Driveways**
 - o Entrance shall be void of all obstacles to a minimum of 30 feet (i.e. light poles, trees, shrubs, stone walls, gates and posts, mailboxes, etc.)
 - o Should be at least 24 feet wide, preferably 28 feet wide
 - o Grade changes cannot change more than 5% in any 75 foot length, with minimal percentage change at changes of direction points (intersections)
 - o Street signs must be installed when roadway is cut
- **Fire Hydrants**
 - o Should be a maximum of 500 feet apart
 - o Should be a maximum of 10 feet off the curb

Respectfully,

Captain Michael Killeen
Fire Prevention Officer
Grafton Fire Department