

# *Town of Grafton*

## Wastewater Treatment Facility

PAUL F. COURNOYER

Superintendent of Sewers

9 Depot Street

South Grafton, MA 01560

Phone: (508) 839.8526 Fax: (508) 839.8523

[cournoyer@grafton-ma.gov](mailto:cournoyer@grafton-ma.gov)

# Memo

**To:** Planning Board  
**From:** Paul Cournoyer  
**Date:** 16 March 2021  
**Re:** 8 Pine Street- Village at Grafton Woods

---

A preliminary meeting was held on March 4<sup>th</sup> between the Grafton Sewer Dept. and Tighe and Bond to discuss the capacity of the wastewater collection system in the area and the proposed relocation of the existing gravity sewer line through the property. There is sufficient capacity in the collection system and the relocation of the gravity sewer line is possible.

Prior to any construction a detailed relocation plan of the gravity sewer line shall be provided to and approved by the Grafton Board of Sewer Commissioners. The plan shall include proposed new sewer line location and easement details. A profile of the proposed line shall also be included.

Prior to any wastewater by-pass a detailed by-pass plan shall also be provided and approved by the sewer dept. staff.

During the demolition process the developer must coordinate with the Grafton Sewer Dept. to assure that the existing sewer services are located and abandoned according to dept. standards.