



Natalia Alward <alwardn@grafton-ma.gov>

100 Westboro Road

1 message

Michael Killeen <killeenm@grafton-ma.gov>

Sat, Mar 12, 2022 at 2:27 PM

To: planningdept@grafton-ma.gov

The Fire Department has not completed a review on this property, but the following are concerns / issues that the Fire Department has:

- There is no clear indication of the width of the entrance / roadway
- There is clear indication of a way for apparatus to turn around
- There is no clear indication of visitor parking to ensure there is no impediment to fire apparatus if there is an incident that requires apparatus to be close

Respectfully,

Captain Michael Killeen
Fire Prevention Officer
Grafton Fire Department